



To: All Prospective Bidders
From: Purchasing Department
Date: April 28, 2017
Subject: Inquiries and Responses
RFP#: 102-2017 250 HP Chilled Water Pump Upgrade

Inquiries and Responses:

- 1) Can I send my bid documents via email?
Official bids cannot be accepted via email. Please review Section II) Submission Instructions in the ITB and use Exhibit C.
- 2) Please confirm the following for each motor and pump:
 - Each Motor requires a new installation of an Aegis grounding ring and ceramic coated bearing for top of motor. **That is correct.**
 - Each Motor needs a new lower bearing (standard) to isolate motor from eddie current. **That is correct.**
 - Each Pump gets a new mechanical seal. **That is correct.**
- 3) How many motors can be done at one time? **Pump 2 and 3 can be done at the same time.**
- 4) Is there a tow motor available to get motors from the roll up door to the truck? **Yes we can provide fork lift.**
- 5) Is there an option that would include a spare motor and seal? **You may list as an option. However, please be sure to note this as an option and make ensure you include what was asked for in the bid.**
- 6) Please provide a roundabout number on the repair and upgrade cost for Chilled Water Pump 2 including rough total building and rough total downtime. **Unfortunately, we are unable to disclose this information during the bidding process.**
- 7) Would there be a forklift available for use when pulling and transferring the motors? **Yes we can provide fork lift.**